



**Council  
Communication**  
Office of the City Manager

**Date**

June 5, 2006

**Agenda Item No.** 47  
**Roll Call No.** ~~06-~~  
**Communication No.** 06-322  
**Submitted by:** Phillip C.  
Vorlander,

**Chief of the Fire Department**

**AGENDA HEADING:**

Amending Chapter 46, Section 1 (C) (27) of the Municipal Code to accurately reference the 2003 International Fire Code.

**SYNOPSIS:**

This section of the Code was inadvertently omitted when the 2003 International Fire Code was adopted by the Council on August 8, 2005.

**FISCAL IMPACT: NONE**

Amount:

Funding Source:

**ADDITIONAL INFORMATION:**

If adopted, the ordinance will cause Chapter 46, Section 1 (C) (27) to accurately reference the 2003 International Fire Code. The ordinance currently references a previous edition of the Code and reads, "Refrigeration equipment. To operate a refrigeration unit or system containing any amount of group 2 or 3 refrigerant or those with group 1 refrigerant and a compressor rating of 100 horsepower or more (see chapter 6 of the fire code)."

The 2003 Code states, "Refrigerant equipment. To operate a refrigeration unit or system having a refrigerant circuit containing more than 220 pounds (100kg) of Group A1 or 30 pounds (14kg) of any other group refrigerant."

**PREVIOUS COUNCIL ACTION(S):**

Date: August 8, 2005

Roll Call Number: 05-1932

Action: Approving adoption of the 2003 International Fire Code Amending Chapter 46 of the Municipal Code, adopting the 2003 International Fire Code. Moved by Brooks that this ordinance do now pass, [#14,473](#). Motion Carried 7-0.

**BOARD/COMMISSION ACTION(S): NONE**

Date:

Roll Call Number:

Action:

**ANTICIPATED ACTIONS AND FUTURE COMMITMENTS:**

Another item on the June 5, 2006 Council agenda recommends action to amend the Schedule of Fees to reflect this change in ordinance.