

★ Roll Call Number

Agenda Item Number

47

Date..... September 24, 2007

An Ordinance entitled, "AN ORDINANCE to amend the Municipal Code of the City of Des Moines, Iowa, 2000, adopted by Ordinance No. 13,827, passed June 5, 2000, and amended by Ordinance No. 14,689 passed August 20, 2007 by amending Section 46-71 thereof, relating to single and multiple station smoke alarms",

presented.

(Council Communication No. 07-565)

Moved by _____ that this ordinance be considered and given first vote for passage.

FORM APPROVED:

(First of three required readings)

Glenna K. Frank
Glenna K. Frank
Assistant City Attorney

COUNCIL ACTION	YEAS	NAYS	PASS	ABSENT
COWNIE				
COLEMAN				
HENSLEY				
KIERNAN				
MAHAFFEY				
MEYER				
VLASSIS				
TOTAL				

CERTIFICATE

I, DIANE RAUH, City Clerk of said City hereby certify that at a meeting of the City Council of said City of Des Moines, held on the above date, among other proceedings the above was adopted.

IN WITNESS WHEREOF, I have hereunto set my hand and affixed my seal the day and year first above written.

City Clerk

MOTION CARRIED

APPROVED

.....
Mayor

ORDINANCE NO. _____

AN ORDINANCE to amend the Municipal Code of the City of Des Moines, Iowa, 2000, adopted by Ordinance No. 13,827, passed June 5, 2000, and amended by Ordinance No. 14,689 passed August 20, 2007 by amending Section 46-71 thereof, relating to single and multiple station smoke alarms.

Be It Ordained by the City Council of the City of Des Moines, Iowa:

Section 1. That the Municipal Code of the City of Des Moines, Iowa, 2000, adopted by Ordinance No. 13,827, passed June 5, 2000, and amended by Ordinance No. 14,689 passed August 20, 2007 is hereby amended by amending Section 46-71 relating to single and multiple station smoke alarms, as follows:


Sec. 46-71. Single and multiple station smoke alarms.

Listed single and multiple-station smoke alarms complying with UL 217 shall be installed in accordance with provisions of this code and the household fire warning equipment provision of NFPA 72.

Smoke alarms in dwelling units shall be addressable with sounder bases and monitored by the building fire alarm system as a supervisory signal only. Mini horns in dwelling units are not required if notification from a building fire alarm system is through the smoke alarms with sounder bases. Section 46-71 only applies to the R-1, R-2, R-4 and I-1 districts as defined in the International Fire Code.

Sec. 2. This ordinance shall be in full force and effect from and after its passage and publication as provided by law.

FORM APPROVED:


Glenna K. Frank
Assistant City Attorney